



**District Level Water Analysis Laboratory Uttar
Pradesh Jal Nigam , Rural , Hapur (245101)**
Test Report



TC-12418

30/09/2026

Test Report No.	UPJN/HPU/618	Issue Date	
Customer's Name	ROYAL HERITAGE INTERNATIONAL SCHOOL	Location of Testing	
Address	ROYAL HERITAGE INTERNATIONAL SCHOOL		
Sampling Method : UPJN(R)QSP/02/2.9	Sample Description – Drinking Water		
Basic Details of Sample			
Quantity of Sample	1 Lit.	Sample ID	UPJN/HPU/30/09/26
Condition of Sample	Plastic Bottle (at Room Temp)	Location of Sampling	ROYAL HERITAGE INTERNATIONAL SCHOOL
Type of Source	Submersible		
District	HAPUR	Block	Hapur
Gram Panchayat	Kamruddin nagar	Village	Nagla chhajju, Samana
Sampling Date	29/9/2026	Sampling Done By	Vikash
Analysis Start Date	30/09/2026	Analysis Completion Date	30/09/2026
Temperature: 25±2 oC		Relative Humidity	50±15%

Technical Data of Analysis

S. No.	Test parameters	Unit of Measurement	Observed Value	Specific requirements as per IS 10500		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	pH at 25°C	-	7.19	6.5-8.5	6.5-8.5	IS 3025 (Part II): 2022
2	Turbidity	NTU	0.60	1	5	IS 3025 (Part 10): 2023
3	Total Dissolved Solids	mg/L	93	500	2000	IS 3025 (Part 16): 2023
4	Chloride (as Cl)	mg/L	22	250	1000	IS 3025 (Part 32): 2019
5	Total alkalinity (as CaCO ₃)	mg/L	180	200	600	IS 3025 (Part 23): 2023
6	Total hardness (as CaCO ₃)	mg/L	200	200	600	IS 3025 (Part 21): 2019
7	Calcium (as Ca)	mg/L	56.2	75	200	IS 3025 (Part 40): 2023
8	Magnesium (as Mg)	mg/L	28.4	30	100	IS 3025 (Part 46): 2023

1. This Test Report only to the particular sample(s) submitted for Analysis.
2. This Test Report shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of
3. The test results reported in this Test Report are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.
5. Water Sample is not Collected by us.

Mukesh Kumar
Prepared by

Mukesh Kumar

Kajal Bhardwaj
Authorized Signatory

Kajal Bhardwaj
Quality Manager

District Level Water Analysis Laboratory
Hapur UPJN
Page 1 of 1

Format No. HPU 7.8.2/1 (Rev. 1)

End of Test Report